



November 29, 2022

ADDENDUM NO. 2

2021 LARGE WATER VALVE AND RCCP REPLACEMENT PROJECT

BID NO. 2023-017

Bidders are directed to revise and incorporate into their bid the following change(s) in bid specifications:

Clarifications

- 1. The City of Mesquite has 2-24" FL x FL valves and 2 - 20" MJ X MJ valves in stock and available for the project.
2. The City of Mesquite will allow one of the 20" MJ x MJ valves it has in stock to be used in lieu of the 24" MJ x MJ valve detailed in the plans and specifications.
3. The City of Mesquite will allow the contractor to use the second 20" MJ x MJ valve it has in stock in place of the third 24" FL x FL valve specified in the plans and specifications.
4. Contractors do not need to restock the 4 valves referred to in line item 1 above.

Revisions

- 1. Replace the corresponding bid proposal sheet in the Contract Documents & Specifications with the one attached, which revises the bid item descriptions for Bid Items 9 and 10 from "Furnish and Install" to "Install" in accordance with line items above and changes the Bid Quantity from 3 to 2 for Bid Item 9 and from 1 to 2 for Bid Item 10.


If you should have any other questions, do not hesitate to contact the Purchasing Office at 972-216-6201, or email purchasing@cityofmesquite.com.

Ryan Williams

Ryan Williams
Manager of Purchasing

ACCEPTANCE:

We, the undersigned, do hereby acknowledge receipt of this Addendum No. 1 to Bid No. 2023-017; 2021 Large Water Valve and RCCP Replacement Project, and agree to the instructions herein written.



The seal appearing on this document was authorized by Richard A. Arvizu, P.E. Tx. No. 88432. Alteration of a sealed document without proper notification to the responsible engineer is an offense under the Texas Engineering Practice Act, 11/29/2022

[Handwritten signature]

Company Name

Authorized Signature

Date

**2021 LARGE WATER VALVE AND RCCP REPLACEMENT PROJECT  
CITY OF MESQUITE CONTRACT NO. 2023-017**

MESQUITE, TEXAS

ITEM NO	BID QTY	UNITS	ITEM DESCRIPTION	UNIT PRICE	AMOUNT
1	532	SY	REMOVE EXISTING CONCRETE STREET PAVEMENT AS SPECIFIED HEREIN, COMPLETE AND IN PLACE	\$	\$
2	39	SY	REMOVE EXISTING CONCRETE SIDEWALK AS SPECIFIED HEREIN, COMPLETE AND IN PLACE	\$	\$
3	125	SY	REMOVE EXISTING CONCRETE DRIVEWAY AS SPECIFIED HEREIN, COMPLETE AND IN PLACE	\$	\$
4	28	SF	REMOVE EXISTING STAMPED CONCRETE MEDIAN PAVEMENT AS SPECIFIED HEREIN, COMPLETE AND IN PLACE	\$	\$
5	94	LF	REMOVE 39" SANITARY SEWER MAIN AS SPECIFIED HEREIN, COMPLETE AND IN PLACE	\$	\$
6	17	LF	REMOVE 4'x2' RCP AS SPECIFIED HEREIN, COMPLETE AND IN PLACE	\$	\$
7	41	LF	REMOVE 24" RCCP WATER MAIN AS SPECIFIED HEREIN, COMPLETE AND IN PLACE	\$	\$
8	2	EA	FURNISH & INSTALL 8" x 8" TAPPING SLEEVE & VALVE AS SPECIFIED HEREIN, COMPLETE AND IN PLACE	\$	\$
9	2	EA	INSTALL 24" RW GATE VALVE FL x FL AS SPECIFIED HEREIN, COMPLETE AND IN PLACE	\$	\$
10	2	EA	INSTALL 20" RW GATE VALVE MJ x MJ AS SPECIFIED HEREIN, COMPLETE AND IN PLACE	\$	\$
11	9	EA	REPAIR OF 24" RCCP WATER MAIN AS SPECIFIED HEREIN, COMPLETE AND IN PLACE	\$	\$
12	4	EA	INVESTIGATION AS SPECIFIED HEREIN, COMPLETE AND IN PLACE	\$	\$
13	1	EA	REHAB EX 4' DIA MH W/ ARMOROCK POLYMER INSERTS AS SPECIFIED HEREIN, COMPLETE AND IN PLACE	\$	\$
14	1	EA	REHAB EX 5' DIA MH W/ ARMOROCK POLYMER INSERTS AS SPECIFIED HEREIN, COMPLETE AND IN PLACE	\$	\$